

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 60153999

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

Date of Issue

0001--27145303 001

25.01.2021

(day/mo/yr)

Genehmigungsinhaber *License Holder*

ELEKTRA ELEKTRONİK SAN. VE TİC. A.Ş
AKÇABURGAZ MAH. 3137 SOK. NO:1
ESENYURT
34522 İSTANBUL
Türkiye

Fertigungsstätte *Manufacturing Plant*

ELEKTRA ELEKTRONİK SAN. VE TİC. A.Ş
AKÇABURGAZ MAH. 3137 SOK. NO:1
ESENYURT
34522 İSTANBUL
Türkiye

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111234137

Geprüft nach *Tested acc. to*

IEC 61558-2-20:2010
EN 61558-2-20:2011

Zertifiziertes Produkt (Geräteidentifikation)

Certified Product (Product Identification)

Lizenzentgelte - Einheit

License Fee - Unit

Reactors (Detuned Filter Reactor)

Type name	: ERH XX/YYY/ZZZ	5
XX	: 07 = The value of detuning factor as $p=\%7$.	1
YYY	: 208, ... , 690 = The value of supply voltage as 208, ..., 690V.	1
ZZZ	: 001, ... , 050, 075, 100 = The value of power as 1 kVAR...100 kVAR.	1

Trademark	: ELEKTRA
Detuning Factor	: $p=\%7$
Supply Voltage	: 208-690 V
IP Class	: IP00
Frequency	: 50 Hz
Max Ambient Temperature	: 40°C
Insulation Class	: Class H

8

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Paulus Hou

**Business Stream Products
Certification Department**

TÜV Rheinland LGA Products GmbH · 90431 Nürnberg

ELEKTRA ELEKTRONİK SAN. VE TİC. A.Ş
AKÇABURGAZ MAH. 3137 SOK. NO:1
ESENYURT
34522 İSTANBUL
Türkiye

TÜV-Bauart-Zeichen o. Akkred. Nr.
R 60153999 0001

ELEKTRA
ERH XX/YYY/ZZZ
IEC 61558-2-20:2010
EN 61558-2-20:2011

,



Paulus Hou

Nein, Dokumentation vorhanden

Contact

Tel. +49 911 655-5225
Mail service@de.tuv.com

Date 25.Ocak 2021

TÜV Rheinland
LGA Products GmbH

Tillystraße 2
90431 Nürnberg

Tel. +49 911 655-5225
Fax +49 911 655-5226
Mail service@de.tuv.com
Web www.tuv.com/safety

Board of Management

Dipl.-Ing.
Jörg Mähler, Spokesman

Dipl.-Kfm.
Dr. Jörg Schlösser

Nürnberg HRB 26013
UST-ID Nr.: DE 811835490

Chairman of the
Supervisory Board

Dipl.-Ing. Raif Scheller